## COPY OF WATER HEALTH AND SANITATION CERTIFICATE

From

The Head

Department of Microbiology

PAU, Ludhiana.

To

The Principal Sant Atar Singh

Akal Acadenty, I hojowall, Dhuri

Ludhiana

Memo, No. 2 357 Dated: 15/05/23

Subject:

Bacteriological quality of drinking water (IS-10500:1991, BIS New Delhi).

Reference is made to your letter No. nil dated 11.05.2023 regarding sample of water for bacteriological analysis.

## REPORT

S. No.	Source	Colifo	rm organisms	Faccal Coliform / E. coli Detected / Not detected
1)		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water sample	Absent	-	Not Detected

INFERENCE .

Bacteriologically safe

:- 01 - note is petable

\*Bacteriologically not safe

:- nil

Technician Technician

Water Testing Lab

Department of Microbiology

PAU, Ludhiana

Incharge

Water Testing Lab

Department of Microbiology

PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

> Head I I I I I Department of Microbiology

\*Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores

Water is safe for Rinking

West Mier Singh Akal Academ. Disti Sangrus Sant Attar Singh Akal Academy BHOJOWALI (Distt. Sangrur) C.B.S.E.Affl. No. 1630695